

SOLAS, Chapter II-2 Regulation 28.1.10 requires that all escape route signs and fire equipment location markings shall be of photoluminescent material or marked by lighting. Photoluminescent material is tested in accordance with DIN 67 510

How to order


1. Choose material **PV**
2. Choose design **100.002**
3. Choose sign size **MS**

PV 100.002 MS

Materials:
PV = Photoluminescent Self Adhesive Vinyl
PR = Photoluminescent Rigid Plast
R = Rigid Plast
V = Self Adhesive Vinyl
A = Aluminium

Size Codes:
A = 25 mm.
B = 30 mm.
C = 50 mm.
D = 65 mm.
E = 75 mm.
F = 80 mm.
G = 95 mm.
H = 100 mm.
I = 105 mm.
J = 120 mm.
K = 140 mm.
L = 148 mm.
M = 150 mm.
N = 200 mm.
O = 210 mm.
P = 250 mm.
Y = 297 mm.
R = 300 mm.
S = 400 mm.
T = 420 mm.
U = 500 mm.
V = 600 mm.
W = 800 mm.
X = 1000 mm.

M = 150 mm. N = 200 mm. Materials: PV



H = 100 mm. R = 300 mm. Materials: PV



M = 150 mm. S = 400 mm. Materials: PV

